

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3774-0544:111

Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Locknetics, 575 Birch Street, Forestville, CT 06010
Contact: Adam O'Day (860) 314-5248 Fax (860) 585-8629*

DESIGN: Model CM5100 cylindrical type with a ½" or ¾" latch bolt electrically controlled single point lock. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Depend on applications, the authority having jurisdiction should be consulted prior to insulation.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as battery operated single point locks. The unit must use with AA Carbon or Alkaline cell batteries only.

*Rev. 06-15-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager